


Approval certificate

Trade waste pre-treatment product



Applicant: Galvin Concrete & Sheetmetal Pty Ltd
Postal address: 40 Motivation Drive, Wangara, WA, 6065

Manufacturer: Galvin Concrete & Sheetmetal Pty Ltd
Address: 40 Motivation Drive, Wangara, WA, 6065

Attention: Jason Leahy
Web: <https://galvinconcrete.com.au>
Email: jleahy@galvins.com.au

Product description

The acceptance certificate applies to the pre-treatment devices of the following size:

Approval Number	Model	Effective Capacity (L)	Placement	External Dimensions (mm)			Inlet / Outlet Diameter (mm)	Inlet Height ¹ (mm)	Outlet Height ¹ (mm)
				L	W	D			
AN-002-01	540	583	Above or Below Ground	1385	940	980	100 / 100	720	690
AN-002-02	1000	1273	Above or Below Ground	2200	1150	1130	100 / 100	820	770
AN-002-03	2000	2299	Above or Below Ground	2400	1150	1530	100 / 100	1250	1200

¹ Invert level

Special conditions of approval

1. The product shall be *supplied* with manufacturer's installation instructions and recommended procedures for operation and maintenance.
2. The product shall be *installed* and *maintained* strictly in accordance to the following Galvin documentation:
 - a. Installation & Maintenance Models 540, 1000 & 2000 (GA-C-M001 Rev 2, dated 30 Nov 2021)
3. Above ground installations must comply with the following additional requirements:
 - i. Bollards are to be installed preventing accidental exterior damage.
 - ii. Bostic® tape is to be used to bond any additional spacers and covers to the trap.
 - iii. The surface under the grease trap will be sufficiently compacted, levelled and removed of all hard objects (i.e. rocks and sticks).
4. This approval certificate is not a stand-alone document and **must be read** in conjunction with the following Water Corporation documents:
 - a. [Typical Drawings for Trade Waste – Grease Arrestor \(HX33-10-00\)](#)
 - b. [Typical Drawings for Trade Waste – Trade waste sampling point \(HX33-11-30\)](#)
 - c. [Typical Drawings for Trade Waste – Venting of trade waste grease arrestors and sealed trade waste sampling points \(HX33-10-10\)](#)
 - d. [Grease Arrestor Installation Guidelines](#)
5. A maintenance contract is to be in place to ensure the ongoing reliability of the product.
6. Water Corporation must be notified within fourteen (14) days upon installation of the product
7. The use of emulsifying agents upstream of the product must not occur. Such instructions must be noted on operating documentation.
8. The product chosen must be suitably sized to avoid surge conditions.
9. Clear access for the purposes of maintenance or servicing of the pre-treatment device must be maintained at all times.
10. This approval certificate is not an endorsement of the product by Water Corporation, and no claim shall be made in advertising, promotion or other manner to the effect.
11. Water Corporation accepts no responsibility for the effective operation, performance or efficiency of the product. This approval is not an engineering approval or structural endorsement.
12. The proponent of the approved product must formally seek a request for re-approval of the product no later than three (3) months before the assigned **Validity Period** has expired from the **Date Issued** of this approval certificate.
13. Water Corporation reserves the right to vary any requirements at any time. Any application of this condition normally occurs after consultation with the manufacturer, supplier and end business user connected to Water Corporation's sewer.

Approval certificate

Trade waste pre-treatment product

Special conditions of approval (continued)

14. Water Corporation shall be notified in writing if the pre-treatment device is withdrawn from sale.
15. The proponent of the approved product accepts that the information provided in this document shall be made publicly available.

General conditions of approval

Approval shall be **suspended** where any of the following conditions are not met:

1. If there is a breach of the Special Conditions.
2. The assigned **Validity Period** has expired from the **Date Issued** of this approval certificate.
3. The product shall be manufactured in accordance with Water Corporation's requirements at the time of approval.
4. The product shall be manufactured to comply according to the details noted in **Installation & Maintenance Models 540, 1000 & 2000 (GA-C-M001 Rev 2, dated 30 Nov 2021)**, in addition to any further details provided by the proponent when seeking this approval.
5. The product supplied for use in Water Corporation's area of operations shall comply with the requirements shown on this approval certificate. Sizes, classes, lengths or other product variables which are available with the product but which are not approved as listed on this approval certificate shall not be offered by the supplier for use in Water Corporation's area of operations.
6. All discharges to sewer associated with this product must not exceed Water Corporation's *Trade Waste Acceptance Criteria*. Where the discharge *has* or is *likely* to exceed the *Trade Waste Acceptance Criteria* then the Corporation may direct a *specific* or *ongoing* maintenance requirement to be followed.
7. Prior to any business (which is connected to Water Corporation's sewer) installing this product the business must apply to Water Corporation for a *Trade Waste Permit* for approval to discharge.
8. If this certificate has been issued to the manufacturer of this product then it is the responsibility of the manufacturer to ensure all current and future suppliers / vendors of this product are provided a copy of this approval certificate.

Approval shall be **reviewed** where any of the following conditions occur:

1. The product is manufactured with either different materials, methods of manufacture, location of manufacture, source of raw materials, component subcontractors or models to that at the time of approval.
2. The ownership of the primary manufacturer or any subcontractors is varied from that at time of approval.
3. The standards and/or specifications to which the product was required to comply with at the time of approval have been amended or revised. It is the responsibility of the proponent to immediately advise Water Corporation of any changes to the proponent's drawings and installation, operation and maintenance manuals made at the time of approval.
4. The product has been found to sustain damage or provide unsatisfactory performance on occasions of number considered excessive by Water Corporation, when handled, stored, assembled or installed in accordance with the supplier's or manufacturer's written instructions.

Approved drawing(s): Installation & Maintenance Models 540, 1000 & 2000 (GA-C-M001 Rev 2, dated 30 Nov 2021)

Authorising person: Stephen Jerkovic (Team Leader – Investigations)

Date issued 01December 2021

Validity period: Five (5) years