

COVER FRAME - PLAN
SCALE: 1:20

RAMSET 1.3t 35mm LONG ANCHOR FITTED IN ACCORDANCE WITH A3850-2003 (4 OFF)


NOTE:
CLASS A COVERS SHALL ONLY BE USED IN PEDESTRIAN AREAS

CLASS C COVERS SHALL BE ONLY LOCATED IN AREAS SUBJECT TO SLOW MOVING TRAFFIC ONLY

MAXIMUM WHEEL LOAD = 7.5 TONNE

NOT TO BE USED IN PUBLIC ROADS OR THOROUGHFARES

- NOTES:**
- BACKFILL TO BE FREE DRAINING SOIL LAID IN 300mm LAYERS (MAX.) AND COMPACTED TO GIVE A MINIMUM COMPACTION OF 7 BLOWS/300mm WHEN TESTED WITH A PERTH STANDARD FALLING WEIGHT PENETROMETER
 - EXTERNAL FITTING SHALL COMPLY WITH THE REQUIREMENT OF THE PLUMBING BY-LAWS
 - WEIGHT OF BASE UNIT: 2 910Kg INCLUDING ALL BAFFLES
WEIGHT OF SPACER: 458Kg
WEIGHT OF COVER FRAME: 1 630Kg INCLUDING ALL BAFFLES
 - FOR STANDARD DETAILS OF GREASE ARRESTOR, CONTACT NAVEI BASE CONCRETE AND REQUEST DAVID WILLS AND ASSOCIATES DRAWINGS:
- 00036 S01D: PLAN AND DETAILS OF TANK
- 00036 S02B: PLAN AND DETAILS OF LID



GREASE ARRESTOR SECTION
SCALE: 1:20

MAXIMUM OF 2 SPACERS PER ARRESTOR TO GIVE A TOTAL MAXIMUM DEPTH OF 2.0m TO UNDERSIDE OF BASE

C	09/08/17	Vent Pipe Diameter Adjusted
B	16/05/11	Amendment to Notes
A	26/03/09	Issued for Comment
REV	DATE	DESCRIPTION
Office Unit 1/9 Shields Crescent BOORAGOON WA 6154 Mail PO Box 3084 MYAREE LPJ WA 6154 phone - (08) 9313 7030 fax - (08) 9313 7040 e-mail - dwa@dwaconsulting.com.au ABN - 34 900 498 130		
CLIENT:		Naval Base Concrete
PROJECT:		Grease Arrestor
DRAWING TITLE: 1000L Grease Arrestor Layout		
SCALE: As Shown		ORIGINAL DRAWING SIZE A3
DESIGNED: D Wills	DATE: 26/03/09	AUTHORISED D Wills
DRAWN: M de Gersigny	DATE: 26/03/09	David Wills AITT(Civil) GradDipB MIEAust CPEng
THIS DRAWING IS COPYRIGHT. USE OR COPYING OF THIS DRAWING IN WHOLE OR IN PART WITHOUT THE WRITTEN PERMISSION OF DAVID WILLS AND ASSOCIATES CONSTITUTES A COPYRIGHT INFRINGEMENT.		
JOB NUMBER: 00036	DWG No: S11	REV No: C