


FOR MORE INFORMATION REFER TO OUR WEBSITE
watercorporation.com.au/tradewaste

GUIDELINES

1. VERTICAL GRAVITY SEPARATORS AND COLLECTION PIT TO BE SIZED ACCORDING TO RATE OF INFLOW. (REFER TO MANUFACTURERS SPECIFICATIONS AND GUIDELINE 7)
2. ONLY NON EMULSIFYING TYPE PUMPS MAY BE USED WITH VERTICAL GRAVITY SEPARATORS.
3. VERTICAL GRAVITY SEPARATORS ARE TO DISCHARGE THROUGH A TRADE WASTE SAMPLING POINT, REFER TO TYPICAL DRAWING HX33-11-30.
4. MAINTENANCE DETAILS TO BE INCLUDED WITH THE APPLICATION TO DISCHARGE TRADE WASTE FORM.
5. ALL MEASUREMENTS SHOWN ARE IN MILLIMETRES.
6. SILT SUMPS ARE NOT RECOMMENDED TO BE USED AS COLLECTION/PUMP PITS.
7. THE MINIMUM CAPACITY OF THE COLLECTION PIT TO BE DOUBLE THE HOLDING CAPACITY OF THE SEPARATOR.
8. ALL ASSOCIATED PLUMBING WORK IS TO COMPLY WITH THE PLUMBERS LICENSING AND PLUMBING STANDARDS REGULATIONS 2000 (THE PLUMBING REGULATIONS) (AS AMENDED)
9. OIL WATER SEPARATOR TO BE A WATER CORPORATION APPROVED PRODUCT. REFER TO WATER CORPORATION WEBSITE FOR LIST OF APPROVED PRODUCTS.
10. ALL ASSOCIATED ELECTRICAL CONNECTIONS TO COMPLY TO AUSTRALIAN STANDARDS AND TO BE INCORPORATED INTO ANY TREATMENT SYSTEM DESIGN
11. IT IS THE BUSINESS OWNERS RESPONSIBILITY TO ENSURE ALL ELECTRICAL WORK IS CERTIFIED BY THE RELEVANT LICENSED TRADESPERSON
12. VERTICAL GRAVITY SEPARATORS ARE TO BE MAINTAINED IN ACCORDANCE WITH MANUFACTURERS INSTRUCTIONS.



E	05/2024		NOTES 10,11 AND 12 ADDED	JD	NT	MS
D	02/2020		PLUMBING REGULATION TITLE UPDATED, NOTE 9 ADDED, FORMERLY TYPICAL DRAWING REFERENCE REMOVED, FRESH AIR INLET ADDED	JMS	NT	MS
C	07/2016		WEBSITE DETAILS ADDED, GUIDELINES AMENDED	BJ	SJ	MS
B	06/2009		NOTES 6,7,8 ADDED & CONTROLLER, STRAINER & BUND ADDED	RJ	GC	AM
ISSUE	DATE	GRID	REVISION	DRN	REC	APPD

SCALE: DIAGRAMMATIC

DES CALC	RECOMMENDED	01/08/2005		WATER CORPORATION		ORIGINAL SHEET SIZE	
DES CHD	A MANZINGER	SENIOR ASSESSMENTS OFFICER		TYPICAL DRAWINGS FOR TRADE WASTE			A3
DRN	APPROVED	01/08/2005		VERTICAL GRAVITY SEPARATOR (VGS)		MF	
K MCGREGOR	J HEWITT	MANAGER, INDUSTRIAL WASTES		FILE	58536682		PLAN
Q.C. CHD				PROJECT	HX33-12-11		E
G CLEAVER							